



State of New Jersey

James E. McGreevey
Governor

Department of Environmental Protection

Division of Environmental Safety, Health,
Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
PO Box 415
Trenton, NJ 08625-0415

Bradley M. Campbell
Commissioner

October 23, 2002

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

To Whom It May Concern:

Subject: Salem Generating Station Units -1 and 2
Docket No. 50-272/50-311
Amendment to Facility Operating License
License Change Request S02-12

The subject request was submitted to the NRC in a letter from PSEG dated September 20, 2002. The request proposes to revise the Salem Technical Specifications TS 3/4.7.11 Fuel Storage Pool Boron Concentration, TS 4/4.7.12 Fuel Assembly Storage in the Spent Fuel Pool, TS 3/4 5.6 Design Features, and TS 3/4.9 Refueling Operations, by establishing a minimum boron concentration in the spent fuel pool to >2300 ppm, and transferring the concentration specification for the Reactor Coolant System during refueling operations, to the Core Operating Limits Report, in accordance with the provisions of the Improved Standard Technical Specifications for Westinghouse plants, NUREG-1431.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering has reviewed the request in accordance with the requirements of 10 CFR 50.91 (b) and has no comments.

If you have any questions, please contact Rich Pinney at (609) 984-7558.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

A001

c: Distribution

Jill Lipoti
N.J. DEP

D. Zannoni
N.J. DEP

R. Bores
NRC Region I State Liaison Officer

R. Lorsen
NRC Sr. Resident Inspector

R. Fretz
NRC Sr. Project Manager

G. Salamon
PSE&G
